

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 95


Dated: 25/3/26

It is certified that an inspection team headed by **Mr. Manish Thacker** Incharge Chemist from **Maintenance Sub Division 8, PHED Indore(MP)** inspected the **Sky Heights Academy at Village Salampur, Betma Dist. Indore (MP)** on 20/03/2026 and on the basis of Water Test Report (Attached) bearing no DW/26/1807 dated 25/03/2026 of **Water Testing Laboratory, Indore (PHED Lab)** certified that the **Sky Heights Academy** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 Year from date of issue.

To,

**Sky Heights Academy
Village Salampur, Betma
Dist. Indore (MP)**


**Assistant Engineer
Maint. Sub Dn. No. 8
IIE, INDORE (M.P.)**

Water Testing Laboratory

Indore Municipal Corporation, Musakhedi, Indore

Test Certificate

Sample from : Sky Heights Academy	Report No:DW/26/1807
Village Salampur , Betma Dist Indore MP	Date of Collection :20/03/26
Sample Details 1ltr Bottle and 250ml SGB	Date of Receipt : 20/03/26
	Completion date : 25/03/26
	Time of Receipt :4.30

S.No.	Tests	Units	Desirable Limit IS-10500-12	Permissible Limit IS-10500-12	Results
A.	Organoleptic and Physical Parameters				
1.	Temperature	°C	----	----	25.1
2.	Colour	Platinum Cobalt Scale	5	15	0
3.	Odour		Agreeable	Agreeable	Agreeable
4.	Turbidity	N.T.U.	1	5	0.31
5.	Total Dissolved Solids	mg/l	500	2000	98
B.	General Parameters Concerning Substances Undesirable in Excessive Amounts				
6.	pH	pH scale	6.5-8.5	No Relaxation	7.32
7.	Alkalinity	mg/l	200	600	31
8.	Total Hardness	mg/l	300	600	39
9.	Chloride	mg/l	250	1000	5
10.	Fluoride	mg/l	1.0	1.5	<0.05
11.	Iron	mg/l	0.3	1.0	<0.05
12.	Calcium	mg/l	75	200	2.0
13.	Magnesium	mg/l	30	100	4.8
14.	Sulphate	mg/l	200	400	2.3
15.	Nitrate	mg/l	45	No Relaxation	1.98
C.	Coliform Count				
19.	Thermo tolerant Coliform Bacteria	CFU/100ml	0	0	0

'BDL ' Below determination limit

Remark:- Tested parameter confirms desirable limit hence safe for drinking.


 Authorized Signatory